

CERTIFICATE OF CONFORMITY

We confirm that the pump type **"NIAGARA C30.10"** complies with the requirements of

EUROPEAN STANDARD EN 1028-1 :2002+A1 :2008

and has been tested in accordance with

EUROPEAN STANDARD EN 1028-2 :2002+A1 :2008

and conforms to the classification:

Fire – fighting centrifugal pump EN1028-1 – FPN 10-3000

Nominal Pressure p_N	10,0 bar
Nominal Delivery Rate	3000 lt/min
Suction Height $H_{s_{geoN}}$	3,0 mt

The High Pressure Pump complies with the requirements of


EUROPEAN STANDARD EN 1028-1 :2002+A1 :2008

under the classification:

Fire – fighting centrifugal pump EN1028-1 – FPH 40-400

Nominal Pressure p_N	40,0 bar
Nominal Delivery Rate	400 lt/min

Ivano Malazzi



Chairman of Maleco S.r.l. Unipersonale